

**Steam-Enhanced Biodegradation of TCE in Mixed
LNAPL Under Active Building
Naval Air Station North Island**

**Battelle 2023
A7 Session**

**Vitthal Hosangadi, Arman Hoseyni, Ryley
Robitaille, Kainalu Asam, Glenn Christensen,
Pamela Chang, Michael Pound**

Project Team



Vitthal Hosangadi, PE (NOREAS) [Presenting]

Arman Hoseyni (NOREAS)

Ryley Robitaille, PE (NOREAS)

Kainalu Asam, EIT (CAPE)

Glenn Christensen, PG (CAPE)

Pamela Chang (Battelle)

Michael Pound (NAVFAC SW)

Acknowledgements: Donald Dressler, PG (NAVFAC SW)

- 1. Introduction/Background**
- 2. Vapor Intrusion Time Critical Removal Action Scope**
- 3. SVE Results**
- 4. Effects of Steam Injection**
- 5. Summary of Results/Lessons Learned**


- **Concerns:**

- Highly used building (379), critical to mission operations, occupants to elevated cVOC levels in indoor air
- cVOCs are dissolved in petroleum hydrocarbon LNAPL

- **Challenges:**


- Reducing cVOCs within LNAPL while protecting building occupants, using a combination of SVE and steam injection
- Demonstrate reduction of source, based on cVOC analyses of LNAPL and other lines of evidence
- Demonstrate anaerobic biodegradation of cVOCs in LNAPL

1.1 Site Location



- B379 has a LNAPL plume (petroleum hydrocarbons) with dissolved cVOCs (TCE and 1,1,1-TCA)
- Vapor Investigations in 2014 indicated elevated levels of cVOCs in indoor air
- A Time Critical Removal Action (TCRA) was initiated for Vapor Intrusion (VI) in 2015

1.2 Conceptual Site Model (Building 379)




Time Critical Removal Action initiated 2015 to address VOCs in Indoor Air

1.3 Background

- In 2014, ~ LF of cracks/joints in the floor were sealed
- SVE started in 2016 with 2 horizontal SVE wells (10 ft bgs), with initial extraction rates > 100 lbs/day (sealing enhanced the ROI)
- In 2017 it was observed that the LNAPL (23 ft bgs) had elevated temperatures (up to 140 °F), due to heat radiating from the Base steam line (6 ft bgs)
- Heating of the soil and NAPL occurred over decades, exacerbating VI
- High temperature (and moisture content) of extracted vapor was impacting the performance of the treatment system (3C system from GEO)
- Initial thought was to mitigate the effects of the steam line (such as vent wells) but instead Navy elected to use the steam to increase the volatilization of cVOCs; since a robust SVE system was already in place
- Steam injection wells (horizontal) were installed in 2017 under the LNAPL, and plumbed into the Base steam; steam was injected from January to June 2018, at which time the Base steam system was discontinued
- Steam injection resumed late 2021 using a steam boiler

2.0 VI TCRA Scope



- Offered relocation to sensitive receptors, modified operation of the ventilation system
- Sealed over 15,000 LF of cracks/joints
- Sealed pathways in restrooms, floor in lunch-room received seal coat
- Deployed Air Purification Units in selected rooms
- Installed 2 dual-screened horizontal SVE well under Building 379
- Extraction started on May 18, 2016
- System enhancements constructed in 2017:
 - 3 new horizontal SVE wells
 - 3 Steam injection wells
 - 2 LNAPL Recovery wells

2.1 VI TCRA Scope



- **Vapors recovered and treated using C3 (condensation/cryogenic/compression) system from GEO**
- **Too rich to treat with GAC/ThOX/CatOX**
- **Extracted vapor is routed through vapor liquid separator**
- **Condenser condenses vapors into liquids:**
 - Condensate filtration
 - Coil coalescing filtration
 - Two heat exchangers
 - Two 1,000-lb activated carbon vessels




3.1 SVE Results: Sub-Slab Vacuum Responses




February 2019 – SVE-1A,B, SVE-2A,B, & SVE-3

August 2019 – SVE-1A,B, SVE-2A,B, & SVE-3



Results in Pascals (Pa)




Most of the building is under vacuum

3.2 SVE Results: Extraction Metrics



Figure 1 - Cumulative Mass Removal Trends of the SVE System



- ~ 9,000 gallons of TPH/cVOCs have been recovered and recycled by the SVE system
- ~18,000 gallons of TPH have been biodegraded aerobically Levels of cVOCs and TPH in extracted vapor have decreased
- **Levels of cVOCs were reduced to acceptable levels after SVE was initiated (and remain low to date)**

3.3 SVE Results: TCE in Indoor Air




- 56 events of indoor air sampling have been completed since 2016
- **No exceedance of ARAL for TCE after SVE operations started in May 2016**
- Levels of TCE in indoor air in the Lunch Room and Women's Restroom were above screening levels prior to SVE
- These decreased significantly after the SVE was initiated – the highest TCE was 2.4 and 1.8 $\mu\text{g}/\text{m}^3$ at these locations

3.4 Transition from Mitigating VI to Source Reduction


- SVE was initially intended to mitigate VI (NAPL at 23 feet bgs, wells screened at 10 feet bgs) by keeping sub-slab under vacuum
- Injection of steam enhanced source reduction – volatilization of dissolved cVOCs was the main intent, **volatilization + anaerobic biodegradation of cVOCs was the result**
- Steam injection was initially done for < 6 months in 2018 (using the same steam that exacerbated VI to begin with)
- Steam injection resumed in late 2021 (after 2 years of planning)

4.1 Effect of 2018 Steam Injection – Extracted Vapor

| No. | Parameter | Before | After |
|-----|--|------------|------------|
| 1 | VOC Reading (PID): SVE-1B Influent | 1,500 ppm | 4,200 ppm |
| 2 | VOC Reading (PID): SVE-3 Influent | 130 ppm | 520 ppm |
| 3 | Temperature of Extracted Vapor | 70 °F | 85 °F |
| 4 | Liquids per day in Effluent of C3 System | 20 gallons | 40 gallons |



4.2 Effect of Steam Injection – Vinyl Chloride in LNAPL



4.2 Effect of Steam Injection –Vinyl Chloride in LNAPL (contd.)

1 Year after Steam Injection stopped



May 2019

NAPL Recovery Wells
SVE Wells
Steam Injection Wells


2 Years after Steam Injection stopped



May 2020


Pink = LNAPL Extent
Green = TCE in LNAPL
Blue = cis-1,2-DCE in LNAPL
Red = VC in LNAPL

3 years after Steam Injection stopped (2nd VC observed)




May 2021


4.2 Effect of Steam Injection – Vinyl Chloride in LNAPL (contd.)



4.3 VC in NAPL and DHC in NAPL-GW Interface (18 months after Steam Injection resumed)



4.4 DHC in NAPL-Groundwater Interface



5.0 Summary of Results/Lessons Learned

- SVE has recovered >9,000 gallons of TPH/cVOCs and an additional >18,000 gallons of TPH have been degraded (aerobically)
- First Steam injection (January to June 2018):
 - Elevated product temperatures observed even 24 months later
 - VC observed in LNAPL (and soil gas) indicating anaerobic biodegradation of TCE within TPH-LNAPL (initially 1 and then 2 locations)
- VC observed at 5 locations after resuming steam injection in late 2021
- DHC thriving in groundwater samples collected from just below LNAPL; confirming that biodegradation (anaerobic) is occurring in LNAPL
- Under the right conditions it is possible to degrade TCE dissolved in TPH-LNAPL

QUESTIONS?