

# Treatment Train for Removing PFAS from High Concentration Stormwater

*John Cuthbertson, Rebecca Mora, Peter Tacy,  
Matthew McCloskey*




# Agenda

- 01 Site Background
- 02 Pretreatment water quality and flow
- 03 Pilot system layout
- 04 Pretreatment design
- 05 Pretreatment results
- 06 PFAS Treatment Results
- 07 Takeaways





# Site Background



0.050 – 0.0150 ppb

**Impacted  
Sediment**

1.5 – 2.4 ppb

1.2 – 2.8 ppb

**Stormwater  
Discharge**

**Groundwater  
Venting**

**Stormwater  
Discharge**



- Surface Water Sample Location



- Former Fire Training Area



- Stormwater Drain



- Stormwater Drain Flow Direction

1.2 – 2.8 ppb

- PFOS Concentration Range in Surface Water



# Water Quality Analysis of Stormwater Drain

		Desired Criteria For IX Resin	Drain SW Sample Baseflow (No Storm)	Drain SW Sample 2" Storm
Compound	Unit			
<b>Diesel Range Organics (Compete for resin space)</b>				
DRO (C10-C28)	ug/L		564	103
<b>Anions (Can reduce resin capacity)</b>				
Bromide	mg/L		< 1.25	< 1.25
Nitrogen, Nitrate	mg/L	<5 mg/L	< 0.250	0.705
Nitrogen, Nitrite	mg/L		< 0.250	0.939
Sulfate	mg/L	<200 mg/L	72.6	45.6
Chloride	mg/L		63.6	213
<b>Metals</b>				
Arsenic	ug/L		1.13	2.62
Calcium	ug/L		57700	45000
Chromium	ug/L		0.989	7.32
Copper	ug/L		1.96	9.74
Iron	ug/L	<500 ug/L	698	2670
Lead	ug/L		0.601	12.9
Magnesium	ug/L		13100	6740
Manganese	ug/L	<20 ppb	635	81
<b>General Chemistry</b>				
Total Alkalinity	mg/L		143	46.1
Total Hardness	mg/L		219	127
Total Dissolved Solids	mg/L		358	482
Total Suspended Solids	mg/L	<1 mg/L	3	35.3
Ferrous Iron	mg/L		0.668	0.272
Ammonia-N	mg/L		< 0.0800	< 0.0800
Total Organic Carbon	mg/L	< 2 ppm	10.2	1.32

- Water quality data was collected during baseflow and a storm event.
- During storm event DRO, Mn and TOC decreased while iron and TSS increased (was expected).
- Iron increase is likely due to iron in stormwater from nearby railroad and recycling facility.

# Flowrate Measurements


- Collected velocity measurements inside culvert, then converted to flow
- Collected readings during baseflow and storm conditions
- Discrete measurements (snap shots) can be affected by WHEN collected during storm event
- Baseflow readings ranged from 5 - 83 gpm (anomalous year)
- Storm event readings ranged from 144 - 551 gpm
- Pilot system designed to operate 100 gpm to ensure baseflow capture and treatment (regulatory driver).






# Pilot Design Basis Summary

- Pilot extraction location based on proximity to open area where pilot system could be built.
- Robust solids removal in pre-treatment system (TSS can have significant impact on IX resin).
- Current pre-treatment includes:
  - 18,000-gallon Weir tank
  - Sand filters
  - Bag filters
- DRO, Metals and TOC data varied based on rainfall conditions.
- Operate pilot and evaluate whether these parameters have an impact on the IX resin performance.
- IX Resin (Purolite PFA694) selected to reduce contact time and be able to treat higher flow rates during significant storm events (looking towards full scale).
- Utilize three IX vessels in series to remove PFAS due to variability of stormwater.
- Regulatory discharge limit of 64 ppt for PFOS.


# Pilot System Location



-  - Pilot System Location
-  - Extraction/Discharge Location
-  - Drain Flow Direction




# Surface Water Extraction to Pilot Treatment System





# Pilot Treatment Design



# Pilot System Equipment



Bag Filters



Sand Filters



Weir Tank



IX Trailer

Sand Filters

Weir Tank



# Pilot System Operation – Phased Approach per Regulatory Permit

- **Phase 1 – Pre-Treatment Operation & Evaluation**

- Evaluate effectiveness of the sediment removal while in IX Resin bypass mode.
- Collect data regarding the critical pre-treatment needs of IX Resin.
  - Daily TSS samples and weekly water quality samples.
- After 2 weeks, went to Phase 2.

- **Phase 2 - PFAS Treatment with IX Resin**

- Evaluate performance under various stormwater flow conditions.
- Evaluate the resin usage rate.
- Pilot will be operational until full-scale system is operational (2024).
- Full-scale design is underway.



# Phase 1 Pre-Treatment Evaluation Results

- Identified DRO, Fe, Mn, and TOC outside the ideal range for Purolite IX resin.
- TSS treatment is effective.
- Following discussions with Purolite, decided to start processing pre-treated water through resin for pilot-scale evaluation.
- Results will be incorporated into full-scale pre-treatment design.

Sample ID	Units	Purolite Desired	SP-INF-Lead-WQ-20230403	SP-INF-Lead-WQ-20230410
Date Collected		Criteria	4/3/2023	4/10/2023
Time Collected			1215	1100
Analyte				
<b>Diesel Range Organics</b>				
DRO	ug/L	ND	345	498
<b>Metals</b>				
Arsenic	ug/L		<0.0680	1.09 J
Calcium	ug/L		46000	128,000
Chromium	ug/L		<0.334	<0.334
Copper	ug/L		2.65	1.46
Iron	ug/L	<500 ppb	162	146
Lead	ug/L		1.34	0.836
Magnesium	ug/L		13400	41800
Manganese	ug/L	<20 ppb	5.73	209
<b>General Chemistry</b>				
Total Suspended Solids (TSS)	mg/L	ND	1.4	<1.0
Total Alkalinity as CaCO3 to pH 4.	mg/L		99.6	317
Total Hardness	mg/L		143	541
Total Organic Carbon	mg/L	<2	2.94 F1	8.21
pH	S.U.		7.71	7.95
Temperature	°C		23.2	22.7



## Phase 2 Initial PFAS Effluent Results (2<sup>nd</sup> Day)

- During the start of Phase 2 (IX Resin treatment), initial influent and effluent samples were collected and analyzed for PFAS (Method 537.1 – 28 compounds).
- Influent results (post pre-treatment):
  - 1080 ppt PFOS
  - 114 ppt PFOA
  - 3,492 ppt Total PFAS
- Effluent results (post IX Resin treatment):
  - 3 ppt PFOS
  - ND for all other PFAS constituents
- Surprised to see a detection of PFOS, need further analytical results to see if this continues.



*Special thanks to Eurofins for expedited turnaround!*

# Key Takeaways and Path Forward

- Stormwater is a different animal than groundwater or industrial effluent treatment.
- Long term piloting is necessary for successful full-scale treatment.
- Upfront groundwater quality evaluation is crucial for identifying pretreatment needs (multiple events to account for different storm events and seasonal changes).
- Understanding flowrates for baseflow and different storm events is critical.
- Pretreatment was able to effectively and systematically removed TSS and turbidity.
- Effects of DRO, Mn and iron on the IX resin will be evaluated during the pilot to better understand prior to full-scale design.
- Treatment for PFAS in stormwater is challenging, but not impossible!

*Special thanks to our engineering team (Rebecca Mora, Matthew McCloskey and Peter Tacy)!*



# Thank You!

John Cuthbertson  
[john.cuthbertson@aecom.com](mailto:john.cuthbertson@aecom.com)  
616-481-4009